



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7011747
Permit #: 01155-2024UPG
Request Rec'd: 09/18/2024
Approval Date: 09/18/2024 DS
Permit Expires: 03/18/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: 2 James, LLC 5850 Hwy 145 Harrisburg, IL 62946 Saline County Contact: Mike Duncan 618/694-9060 | FACILITY - name and address where tanks are located: Mitchellville Country Store 5850 Highway 145 South Harrisburg, IL 62946 Saline County Contact: Mike Duncan 618/252-6414 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 5 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 7 | Gasoline - Premium | 4,000 | Currently in use | Federal |
| 8 | Diesel Fuel | 30,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection - West | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection - West |

Summary of Work

Removing incon electronic leak detection on tank 5,7 and 8 installing Mechanical leak detection on 5, 7 and 8.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
128 Millwell Drive
Maryland Heights, MO 63043

Contact Person: Terry Smith
Phone: 314/797-0468
Email: cbayne@unitedpetro.com
Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks