



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 3009225  
Permit #: 01157-2024UPG  
Request Rec'd: 09/18/2024  
Approval Date: 09/18/2024 DS  
Permit Expires: 03/18/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Gold Star FS, Inc. 13125 IL Hwy 81 Cambridge, IL 61238 Henry County Contact: Ethan Washburn 815/499-9766	<b>FACILITY</b> - name and address where tanks are located: Gold Star FS Petroleum Bulk Plant 13495 IL Highway 81 Cambridge, IL 61238 Henry County Contact: Ethan Washburn 815/499-9766
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Non Ethanol	10,000	Currently in use	Federal
3	Gasoline - Regular	15,000	Currently in use	Federal
4	Diesel Fuel	15,000	Currently in use	Federal
5	Diesel Fuel	20,000	Currently in use	Federal
6	Dyed Diesel	20,000	Currently in use	Federal
7	Dyed Diesel	20,000	Currently in use	Federal
8	Dyed Diesel	20,000	Currently in use	Federal
10	Dyed Diesel	30,000	Currently in use	Federal
11	Dyed Diesel	30,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

**Tank 4 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

**Tank 5 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

**Tank 6 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

**Tank 7 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

**Tank 8 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

**Tank 10 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors - T-9 Interstitial

**Tank 11 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors - East

**Summary of Work**

Replacing the existing Vedder Root TLS 350 with new Incon EVO 600

**Special Contingencies**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Contact Person: Glen Davis  
Phone: 563/340-5216  
Email: gdavis@senecaco.com  
Contractor License # IL598 Exp. 2/23/2026

Sincerely,



---

Daniel Starks