

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2019748
Permit #: 01158-2024CAT
Request Rec'd: 09/18/2024
Approval Date: 09/18/2024
Permit Expires: 03/18/2025

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS- Corporation, partnership, or other business entity:
Ford Motor Company

290 Town Center Drive, Suite 800 Dearborn, MI 48126 Wayne County

Contact: Ann McCormick 313/805-6446

FACILITY

- name and address where tanks are located:

Chicago Assembly Plant 12600 South Torrence Avenue Chicago, IL 60633 Cook County

Contact: Jake Hoitsma 773/646-7472

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 6 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 7 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 9 | Xylene | 12,000 | Currently in use | Federal |
| 12 | Xylene | 12,000 | Currently in use | Federal |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|------------------------|----------------------------|---|
| Corrosion Protection - | Impressed Current Cathodic | Replacing - Corrosion Prot - Tank - Impressed Current |
| Tank | Protection | Cathodic Protection |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------------|---------------------------------------|---|
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------------|---------------------------------------|---|
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection |

Tank 12 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------------|---------------------------------------|---|
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection |

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Repair CP Impressed Anodes for Tanks #6 & #7 & #9 & #12 (4 Tanks) using Hydro Drillers and GPR private locate radar. Any questions please contact me Frank Grebas 414-397-1469

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC

658 North Progress Drive PO Box 80265

Saukville, WI 53080

Contact Person: Kylie Krombach

Phone: 262/268-1150

Email: frankg@protanicinc.com

Contractor License # IL1413 Exp. 3/15/2026

Sincerely,

Sean Keane