



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2022887
Permit #: 01138-2024UPG
Request Rec'd: 09/13/2024
Approval Date: 09/16/2024 DS
Amended Date: 09/23/2024 DS
Permit Expires: 03/18/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: J & B Oaklawn, Inc. 5970 W. 95th Street Oak Lawn, IL 60453 Cook County Contact: Jibby Thomas 630/220-7194	FACILITY - name and address where tanks are located: Oak Lawn Express Mart, Inc. 5870 W. 95th Street Oak Lawn, IL 60453 Cook County Contact: Musleh Sharif 630/220-7194
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Regular	12,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New

Summary of Work

We cutting and capping the vent line for tank 8 temporarily until tank 7 gets abandoned as per OSFM and will reconnect after the abandonment is finished by Removal Contractor
But when we went and checked its vapor line so no need to do any repairs to vent line

Special Contingencies

Amendment Reason:

The line that is blocking is a vapor line not a vent line and the site is completely down

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks