



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2018354
Permit #: 01170-2024UPG
Request Rec'd: 09/23/2024
Approval Date: 09/23/2024
Permit Expires: 03/25/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Gas Express, Inc. 501 W. 31st Street Chicago, IL 60616 Cook County Contact: Vince Scalise 312/622-6883	FACILITY - name and address where tanks are located: Citgo / Gas Express 501 W. 31st Street Chicago, IL 60616 Cook County Contact: Vince Scalise 312/634-5871
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Premium	8,000	Currently in use	Federal
7	Gasoline - Regular	15,000	Currently in use	Federal
8	Diesel Fuel	2,000	Currently in use	Federal
10	Diesel Fuel	6,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Removing

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Removing

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Removing

Summary of Work

the tank testing leak detection will be removed. The site will utilize the existing tank interstitial monitoring as the sole method of tank leak detection.


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: ed.angell@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive, flowing style. Below the signature is a solid horizontal line.

Sean Keane