

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2013545
Permit #: 01176-2024LIN
Request Rec'd: 09/24/2024
Approval Date:09/24/2024 DS
Permit Expires: 03/25/2025

# <u>Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances</u>

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.** 

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

LACOA

19N58 Aztec Lane Huntley, IL 60142

McHenry County

Contact: MATT METELAK 847/854-6958

**FACILITY** 

- name and address where tanks are located:

Landings Airstrip Corporation

19 N 58 Aztec Lane Huntley, IL 60142 McHenry County

Contact: BRIAN EGAN 847/624-0205

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
2	Aviation Fuel	4,000	Currently in use	Federal	Existing
3	Gasoline - Mid-grade	4,000	Currently in use	Federal	Existing

#### **Summary of Work**

Excavate area over tanks. Purge, clean, inspect and re-certify the internal lining of the following tanks in accordance with EPA 280 and State of Illinois 175 regulations. Furnish and install manways with access to grade.

### **Special Contingencies**

DEDSON	FTDM OD	COMPANY	PERFORMING	WODK.

ef J. Starke

Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086 Contact Person: Clayton Bennett

Phone: 262/623-0300

Email: paula@armorshieldus.com

Contractor License # IL1707 Exp. 4/18/2026

Sincerely,

Daniel Starks