



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2044182
Permit #: 01179-2024UPG
Request Rec'd: 09/24/2024
Approval Date: 09/24/2024 DS
Permit Expires: 03/25/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Village of Wheeling 77 W. Hintz Rd. Wheeling, IL 60090 Cook County Contact: Lana Rudnik 847/344-0096	FACILITY - name and address where tanks are located: Village of Wheeling 77 W. Hintz Road Wheeling, IL 60090 Cook County Contact: Lana Rudnick 847/344-0096
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Diesel Fuel	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New
Piping	Fiberglass Single Wall Piping Ameron 4000 L single wall vent	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Piping	Fiberglass Single Wall Piping Ameron 4000 L single wall vent	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing all risers on each tank

Installing new double wall spill buckets on each tank

Installing new overfill drop tubes on each tank


Replacing the underground portion of the vent piping with Ameron single wall 3000L (No issues with vent pipe, owner just wants it replaced while excavation is open)

Special Contingencies**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 630/878-6354
Email: jasonre@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks