



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2036100  
Permit #: 01206-2024UPG  
Request Rec'd: 09/27/2024  
Approval Date: 09/30/2024 DS  
Permit Expires: 04/01/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Bell Fuels, Inc. 1515 Creek Drive Morris, IL 60450 Grundy County Contact: George Sweeney 815/416-1060	<b>FACILITY</b> - name and address where tanks are located: Flyers Energy, LLC d/b/a Quick Fuel #3145 1285 North Ellis Bensenville, IL 60106 Du Page County Contact: Anais maurel 530/885-0401
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal
3	Gasoline - Regular	6,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Piping	Fiberglass Double Wall Ameron	Replacing - Piping - Fiberglass Double Wall Ameron
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Gilbarco EMC with CSLD

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron	Replacing - Piping - Fiberglass Double Wall Ameron
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Gilbarco EMC with CSLD

**Dispensers on the Permit**

Dispenser	Action
1/2	Replacing - 1/2
3/4M	Replacing - 3/4
4S/5M	Replacing - 5
5S/6M	Replacing - 5S/6
6S/7	Removing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

**Dispenser 3/4M Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

**Dispenser 4S/5M Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

**Dispenser 5S/6M Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor	Removing

**Dispenser 6S/7 Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

**Summary of Work**

Removing (4) pump islands and (5) dispenser sumps. The first island currently has 2 sumps. Only one sump will be installed at that island making a total of 4 new sumps. Installing new bravo sumps and pouring new islands. Installing a new veeder root 450Plus with CSLD.

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/606-0996 Email: nickb@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks