



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1017668  
Permit #: 01209-2024REM  
Request Rec'd: 09/27/2024  
Approval Date: 09/30/2024 DS  
Permit Expires: 04/01/2025

## **Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances**

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Elizabeth Sauser 210/692-2224	<b>FACILITY</b> - name and address where tanks are located: Circle K #1310 1500 North Columbus Ottawa, IL 61350 LaSalle County Contact: Justin Travis 815/431-1948
--	--

### **Tanks on the Permit For Piping Only**

<b>Tank #</b>	<b>Capacity</b>	<b>Product</b>	<b>Last Used Date</b>
5	12,000	Gasoline - Regular	
6	12,000	Diesel Fuel	
7	12,000	Gasoline - Premium	
8	6,000	Kerosene	

### **Summary of Work**

Removal of all existing product piping for the installation of new NUPI pipe and new STP & UDC containment sumps. All tank vent piping to remain in place

### **Special Contingencies**

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & B Construction & Excavating Company 1288 East Bungalow Road Morris, IL 60450	Contact Person: Linda Goldsmith Phone: 815/416-1330 Email: dcarlson@bbconstinc.com Contractor License # IL1602 Exp. 10/6/2024

Sincerely,

Daniel Starks