



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2005467
Permit #: 01211-2024UPG
Request Rec'd: 09/27/2024
Approval Date: 09/30/2024 DS
Permit Expires: 04/01/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60805 Cook County Contact: Nathan DeAngeles 708/229-6112	FACILITY - name and address where tanks are located: Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60805 Cook County Contact: Nathan DeAngeles 708/229-6112
---	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	10,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OmegaFlex DoubleTrac	Replacing - Piping - Flexible Double Wall OmegaFlex DoubleTrac

Summary of Work

NOTE: THIS PERMIT IS REPLACING 00601-2024UPG (replaced permit #01276-2022UPG)
The underground tank has (1) existing 1 inch fuel supply line to the building generator. The existing fuel line will be replaced by the new. The new pipe will be (1) 1 inch OmegaFlex brand pipe from the UST to the building. The route for the new pipe is not in the same trench as the old pipe. When the new pipe is installed the old pipe will be disconnected from the tank and drained and then abandoned in place under a separate permit. The change over from the old pipe to the new pipe will happen within a few hours so as not to take the generator system off line for more than 2 hours. There is no change to the tank top containment. The tank top containment is only a cylinder to keep gravel away and not a containment sump. There is NO change to the vent pipe, fill or other fuel system components. There is NO fuel return line.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: yvonne@crownetank.com Contractor License # IL002345 Exp. 5/16/2026

Sincerely,

Daniel Starks