



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2016461
Permit #: 01234-2024UPG
Request Rec'd: 10/03/2024
Approval Date: 10/03/2024
Permit Expires: 04/03/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101 (None) County Contact: Jeremy Holland 610/625-8061	FACILITY - name and address where tanks are located: IL0131 2807 W. 71st Street Chicago, IL 60629 Cook County Contact: Bruce Hill 847/680-5831
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Mid-grade	4,000	Currently in use	Federal
3	Gasoline - Regular	4,000	Currently in use	Federal
4	Gasoline - Regular	4,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket
Piping	Other Steel Riser	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Other Steel Riser	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Other Steel Riser	New

Summary of Work

We are converting the Mid grade tank to the Regular by manifolding the lines inside the STP containments. Cap/plug the Mid grade lines under the dispensers .

Thank you

Innovative Construction


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Innovative Constructions Technology LLC
245 W Roosevelt Rd Building 4, Unit 28
West Chicago, IL 60185

Contact Person: Raju penumatsa
Phone: 630/747-3404
Email: iconstructions81@gmail.com
Contractor License # IL002453 Exp. 2/7/2026

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive, flowing style. Below the signature is a solid horizontal line.

Sean Keane