



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3006090
Permit #: 01246-2024UPG
Request Rec'd: 10/07/2024
Approval Date: 10/07/2024 DS
Permit Expires: 04/08/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Bushnell Food Mart, Inc. 859 N. Cole Street Bushnell, IL 61422 McDonough County Contact: Satwinder Singh 815/307-4839	FACILITY - name and address where tanks are located: Fushnell Food Mart 859 N. Cole St. Bushnell, IL 61422 McDonough County Contact: Satwinder Singh 815/307-4839
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Regular	12,000	Currently in use	Federal
8	Gasoline - Premium	6,000	Currently in use	Federal
9	Diesel Fuel	6,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

Tank 7: Replacement of SW Spill Bucket with DW Bucket, Install of New OPV
Tank 8: Replacement of SW Spill Bucket with DW Bucket, Install of New OPV
Tank 9: Replacement of SW Spill Bucket with DW Spill Bucekt, Install of New OPV

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Glen Davis
Phone: 563/340-5216
Email: gdavis@senecaco.com
Contractor License # IL598 Exp. 2/23/2026

Sincerely,



Daniel Starks