



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 312/745-3162
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2023013 |
| Permit #: | 01245-2024UPG |
| Request Rec'd: | 10/07/2024 |
| Approval Date: | 10/07/2024 |
| Permit Expires: | 04/08/2025 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Full West BP Corporation 2357 W. Fullerton Ave. Chicago, IL 60647 Cook County Contact: PatThachet 773/203-0048 | FACILITY - name and address where tanks are located: Amoco Ss#15500 Fac#10749 2357 W. Fullerton Ave. Chicago, IL 60647 Cook County Contact: Pat Thachet 773/772-0704 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 7 | Gasoline - Premium | 12,000 | Currently in use | Federal |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |
| Piping | Fiberglass Single Wall Piping Ameron Dualoy 3000/L | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| Piping | Other Submersible Pump | New |

Summary of Work

Installing new single wall fiberglass tank containment sump, new submersible and mechanical line leak detector. new single wall fiberglass pipe connected to existing steel pipe and run back into the new sump.

Special Contingencies

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2026 |

Sincerely,

Sean Keane

For Office Use Only

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|--------------------------------|---------------|
| Piping | Not Installed STP/Tanktop Sump | Removing |