



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 6028367  
Permit #: 01256-2024UPG  
Request Rec'd: 10/08/2024  
Approval Date: 10/08/2024 DS  
Permit Expires: 04/08/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: City of Alton 101 E. 3rd St, Room 203 Alton, IL 62002 Madison County Contact: Steven Palen 618/463-3530	<b>FACILITY</b> - name and address where tanks are located: City of Alton Public Works Center #2 Emma Kaus Lane Alton, IL 62002 Madison County Contact: Watt Hubert 618/463-3530
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	15,000	Currently in use	Federal
2	Gasoline - Regular	15,000	Currently in use	Federal
3	Used Oil	600	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

**Dispensers on the Permit**

Dispenser	Action
1	Replacing - 1
2	Replacing - 2

**Dispenser 1 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

## Dispenser 2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New


### Summary of Work

New tank sump lids will be installed on all three tank sumps. The existing flex connectors and steel piping in the tank sumps will be replaced. Any existing entry boots that are in disrepair will be replaced. New dispensers and single wall dispenser containment sumps will be installed. The existing flex connectors and emergency valves will be replaced. Any existing CP protection in any of the dispenser sumps and tank sumps will be removed. The existing double wall FRP piping will be cut back to install the dispenser sumps and reinstalled into the new dispenser sumps.

### Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/797-0468 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks