

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2047813 Permit #: 01267-2024ABN Request Rec'd: 10/09/2024 Approval Date: 10/09/2024 Permit Expires: 04/09/2025

<u>Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

NBC Partners LLC 3433 W 48th Place Chicago, IL 60632

Contact: Stephen Cornwell 773/523-3100

FACILITY

- name and address where tanks are located:

Accu-Labs, Inc. 3433 W 48th Place Chicago, IL 60632 Cook County

Contact: Stephen Cornwell 773/523-3300

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
1	10,000	Heating Oil	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

The UST is in a building and within 2 feet of an outside wall so removing the UST would threaten the structural integrity of the building. Therefore Removal is infeasable.

Special Contingencies

PERSON,	FIRM	OR	COMPANY	PERFORMING	WORK:

Chicago Environmental, Inc. 2333 Wisconsin Avenue Downers Grove, IL 605154022 Contact Person: David Streich Phone: 630/776-0024

Email: david@chicagotankremoval.com Contractor License # IL002444 Exp. 4/6/2026

Sincerely,

Sean Keane