



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2022920
Permit #: 01275-2024UPG
Request Rec'd: 10/10/2024
Approval Date: 10/11/2024
Amended Date: 10/11/2024 Chi
Permit Expires: 04/11/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Omsri Properties, LLC 6350 W. Montrose Avenue Chicago, IL 60634 (None) County Contact: Kishore Kumar Gunda 773/430-1226	FACILITY - name and address where tanks are located: Omsri Properties, LLC 6350 W. Montrose Avenue Chicago, IL 60634 Cook County Contact: Kishore Kumar Gunda 773/430-1226
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - North Regular	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North Regular
Spill Containment Device	Double Wall Spill Bucket - North Regular	Replacing - Spill Contain Device - Single Wall Spill Bucket - North Regular

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

Both spill and drop tube failed inspection so replacing both of them


Special Contingencies

Amendment Reason:

The drop tube on tank 1 is also so replacing spill and drop tube on Tank1

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

A handwritten signature in black ink that reads "Seán Keane". The signature is written in a cursive style with a horizontal line underneath the text.

Sean Keane