

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2009105
Permit #: 01284-2024UPG
Request Rec'd: 10/14/2024
Approval Date:10/15/2024 DS
Permit Expires: 04/15/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101

(None) County

Contact: Jeremy Holland 610/625-8061

**FACILITY** 

- name and address where tanks are located:

IL0097

3321 Algonquin Road Rolling Meadows, IL 60008

Cook County

Contact: Dan Patel 847/222-9668

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Gasoline - Premium	12,000	Currently in use	Federal
11	Diesel Fuel	12,000	Currently in use	Federal

#### **Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve OPW 53	Removing

#### **Tank 11 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve OPW 53	Removing

#### **Summary of Work**

Remove ball floats as an overfill method. Tank 9 & 11 permit for overfill alarm only

### **Special Contingencies**

Oaniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: amberp@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026			

Sincerely,

Daniel Starks