



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6000637
Permit #: 01307-2024UPG
Request Rec'd: 09/24/2024
Approval Date: 10/16/2024 DS
Permit Expires: 04/16/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Luhr Bros., Inc. 250 W. Sand Bank Rd. P.O. Box 50 Columbia, IL 62236 Monroe County Contact: Mike Luhr 618/281-4106	FACILITY - name and address where tanks are located: Luhr Bros., Inc. 250 W. Sand Bank Rd. Columbia, IL 62236 Monroe County Contact: Mike Luhr 618/281-4106
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Motor Oil	1,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX

Summary of Work

We are requesting to repair the product piping on tank 11 due to a failed precision line test. The failure has been identified and the system has been taken offline. Customer is monitoring sensor reports for any changes in status. All materials have been placed on order and a plan for correction has been created. We plan to replace 20ft of pipe within the system. The existing piping sump entry will remain the same with a new boot being placed and a containment integrity test being preformed

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Superior Acquisition LLC d/b/a Superior Equipment Company 7525-A Sussex St. Louis, MO 63143	Contact Person: Matt Gross Phone: 314/644-6000 Email: Mgross@secofuel.com Contractor License # IL002394 Exp. 3/8/2025

Sincerely,

Daniel Starks