



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	3007068
Permit #:	01308-2024CAT
Request Rec'd:	10/16/2024
Approval Date:	10/16/2024 DS
Permit Expires:	04/16/2025

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Morton Gas Company II 400 West Birchwood Morton, IL 61550 Tazewell County Contact: Ashraf Sayeed 630/205-6372	<b>FACILITY</b> - name and address where tanks are located: Morton Gas Company II 400 West Birchwood Morton, IL 61550 Tazewell County Contact: Ashraf Sayeed 309/550-5150
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Diesel Fuel	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Installing sacrificial anodes on flex connectors and piping at the UST submersible containment sumps due to existing anodes being gone.

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Total Petroleum Service Company  
2421 Washington Road  
Washington, IL 61571

Contact Person: Cheri McCoy  
Phone: 309/694-8224  
Email: Tom.Oltman@TotalPetroleum.net  
Contractor License # IL1079 Exp. 2/8/2026

Sincerely,

  
\_\_\_\_\_

Daniel Starks