



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2027788  
Permit #: 01313-2024CAT  
Request Rec'd: 10/16/2024  
Approval Date: 10/17/2024 DS  
Permit Expires: 04/17/2025

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: 590 Lake Properties, LLC 590 W Lake Street Roselle, IL 60172 Du Page County Contact: Sebil Joseph 847/682-6504	<b>FACILITY</b> - name and address where tanks are located: Roselle Food Mart, Inc. 590 W. Lake Street Roselle, IL 60172 Du Page County Contact: Sebil Joseph 847/682-6504
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Diesel Fuel	12,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection - STP Sump	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - STP Sump

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection - STP Sump	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - STP Sump

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection - STP Sump	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - STP Sump

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Th application is for installing replacement sacrificial anodes for all the USTs and the Product Piping. Two (2) 32lb. High Potential Magnesium Anodes will be installed on each UST and five (5) 17lb. High Potential Magnesium Anodes on the Product Piping and connected to existing wires.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Advanced Corrosion Control Technologies., Inc. 4664 North DuBay Drive Mosinee, WI 54455	Contact Person: Timothy Sievert Phone: 262/960-3665 Email: timothysievert@gmail.com Contractor License # IL2072 Exp. 3/22/2026

Sincerely,



Daniel Starks