



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Replacement of 00162-2024INS

FOR OFFICE USE ONLY
Facility #: 2021368
Permit #: 01318-2024INS
Request Rec'd: 10/17/2024
Approval Date: 10/17/2024 DS
Permit Expires: 04/17/2025

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Glenview Enterprise, Inc. 1 East St. Charles Rd. Villa Park, IL 60181 (None) County Contact: Wasim Khawja 630/776-3474	FACILITY - name and address where tanks are located: Glenview Enterprise, Inc. 1023 W. Main Street St. Charles, IL 60174 Kane County Contact: Muhammad Younus 630/776-3474
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Premium	5,000	Installed/Not in Use	Federal
5	Gasoline - Regular	12,000	Installed/Not in Use	Federal
6	Diesel Fuel	5,000	Installed/Not in Use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Overfill Prevention Device	Overfill Alarm	New
Piping	Ball Valves	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Corrosion Protection - Tank	Jacketed Steel Non-Corrosive	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Shear Valves	New
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Piping	Positive Shutoff Valves	New
Piping	Other Submersible Pump	New
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	New
Tank	Composite Double Wall Lannon	New
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Overfill Prevention Device	Overfill Alarm	New
Tank	Composite Double Wall Lannon	New
Piping	Positive Shutoff Valves	New
Piping	Ball Valves	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	New
Corrosion Protection - Tank	Jacketed Steel Non-Corrosive	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Shear Valves	New
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Overfill Prevention Device	Overfill Alarm	New
Tank	Composite Double Wall Lannon	New
Piping	Positive Shutoff Valves	New
Piping	Ball Valves	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	New
Corrosion Protection - Tank	Jacketed Steel Non-Corrosive	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Shear Valves	New
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New

Dispensers on the Permit

Dispenser	Action
1/2	New
3/4	New
5/6	New

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.

There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

Tank and tank install along with tank air test was completed on 2/8/2024 under permit # 00420-2023INS

Permit # 00162-2024INS - final inspection - was void - Partially Executed

Applicant # IL002464

we changed our name from U.S. Venture to EnergiTech Services - see supplemental documents

Special Contingencies

NOTES: Dispensers must be a full 10' from all buildings and property lines. Vents must meet section 175.440 of our rules.

Revision Reason:

Removed double wall flexible piping

Replacement Reason:

Site not ready for final inspection on 10/9/2024

PERSON, FIRM OR COMPANY PERFORMING WORK:	
EnergiTech Services, LLC 558 Carter Court Kimberly, WI 54136	Contact Person: Larry Smarzinski Phone: 920/243-6292 Email: jcollins@energitechservices.com Contractor License # IL002464 Exp. 2/6/2026

Sincerely,



Daniel Starks