

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2039335
Permit #: 01329-2024UPG
Request Rec'd: 10/19/2024
Approval Date:10/21/2024 DS
Permit Expires: 04/22/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County

Contact: Zachery Davis 937/203-7827

FACILITY

- name and address where tanks are located:

Speedway #1417 4032 Route 34 Oswego, IL 60543 Kendall County

Contact: Debbie 630/551-3310

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|----------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 2 | Gasoline - Mid-grade | 8,000 | Currently in use | Federal |
| 3 | Gasoline - Premium | 8,000 | Currently in use | Federal |
| 4 | B-11 | 8,000 | Currently in use | Federal |
| 5 | E85 | 2,000 | Currently in use | Federal |
| 6 | Kerosene | 2,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|--|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Summary of Work

Replacing leak detector and TLS 350 with TLS450 Plus and DPLLDs

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | |
|--|--|--|
| America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504 | Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025 | |

Sincerely, Daniel J. Starks

Daniel Starks