



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2014595 |
| Permit #: | 01332-2024UPG |
| Request Rec'd: | 10/19/2024 |
| Approval Date: | 10/21/2024 DS |
| Permit Expires: | 04/22/2025 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachery Davis 937/203-7827 | FACILITY - name and address where tanks are located: Speedway 7616 115 N. 8th Street West Dundee, IL 601182013 Kane County Contact: Store Manager 847/428-6070 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 5 | Gasoline - Regular | 20,000 | Currently in use | Federal |
| 6 | Gasoline - Premium | 12,000 | Currently in use | Federal |
| 7 | Diesel Fuel | 4,000 | Currently in use | Federal |
| 8 | B-11 | 4,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Summary of Work

Replacing leak detector and TLS 350 with TLS450 Plus and DPLLDs

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504 | Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025 |

Sincerely,



Daniel Starks