

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2009029
Permit #: 01334-2024UPG
Request Rec'd: 10/19/2024
Approval Date:10/21/2024 DS
Permit Expires: 04/22/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Hanumandada Holdings, LLC 4002 W. Dempster Street Skokie, IL 60077 Cook County

Contact: Girish Gheewala 773/209-9402

**FACILITY** 

- name and address where tanks are located:

Bucky's Express #6424 4002 Dempster Street Skokie, IL 60076 Cook County

Contact: Kevin Gheelwala 515/446-6238

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	10,000	Currently in use	Federal

### **Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

#### **Summary of Work**

The drop tube is stuck so replacing both drop tube and spill bucket

#### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services

4075 Fox Valley Center Dr., Unit 9

Janiel J. Starke

Aurora, IL 60504

Contact Person: Ravindra Penmatsa

Phone: 312/286-6722 Email: ravi@ampsco.net

Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks