



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2045625
Permit #: 01348-2024UPG
Request Rec'd: 10/22/2024
Approval Date: 10/22/2024 DS
Permit Expires: 04/22/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: XPO Logistics Freight, Inc. 2211 Old Earhart Rd., Suite 100 Ann Arbor, MI 48105 (None) County Contact: Jerry Krawiec 734/757-1657	FACILITY - name and address where tanks are located: XPO Logistics Freight, Inc. - XJO 1950 Terminal Court Joliet, IL 60436 Will County Contact: Jamie Regan 779/225-1001
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal
2	Diesel Fuel	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Dispensers on the Permit

Dispenser	Action
#1	Replacing - #1
#1 SAT	Replacing - #1 SAT
#2	Replacing - #2
# 2 SAT	Replacing - # 2 SAT
# 3	Replacing - # 3
# 3 SAT	Replacing - # 3 SAT

Dispenser #1 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser #1 SAT Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser #2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Double Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser # 2 SAT Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser # 3 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser # 3 SAT Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Summary of Work

Replace the diesel dispensers and repalce the tank monitor with a Veeder Root 450 Plus.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 600903936	Contact Person: Warren Cherner Phone: 847/465-4000 Email: info@metrotank.com Contractor License # IL102 Exp. 2/7/2026

Sincerely,



Daniel Starks