



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2021070
Permit #: 01357-2024UPG
Request Rec'd: 10/23/2024
Approval Date: 10/23/2024
Permit Expires: 04/23/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: JSJK Western Properties, Inc. 6000 N. Western Chicago, IL 60659 Cook County Contact: Soji Mathew 847/208-9284	FACILITY - name and address where tanks are located: Shell Station 6000 N. Western Chicago, IL 60659 Cook County Contact: Soji Mathew 847/208-9284
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve


Summary of Work

WE ARE INSTALLING TANK 1 REGULAR AND TANK 3 PREMIUM OPW DOUBLE WALL SPILL BUCKET WITH NEW RAISER AND DROP TUBE

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
MKEQS Inc. 2860 S River Road, STE 470 Des Plaines, IL 600186008	Contact Person: Madhu Kiran Patibandla Phone: 630/649-8699 Email: kiranp@mkeqs.com Contractor License # IL002468 Exp. 10/21/2026

Sincerely,

A handwritten signature in black ink that reads "Seán Keane". The signature is written in a cursive style with a horizontal line underneath the text.

Sean Keane