

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 4013186
Permit #: 01381-2024CAT
Request Rec'd: 10/29/2024
Approval Date:10/30/2024 DS
Permit Expires: 04/30/2025

# <u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821 White County

Contact: Landon Bayley 618/382-2334Ext.248

**FACILITY** 

- name and address where tanks are located:

Hucks #173

1000 North State Highway 121

Mount Zion, IL 62549

Macon County

Contact: Jon Kaeding 618/382-2334

#### Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	15,000	Currently in use	Federal
7	Diesel Fuel	15,000	Currently in use	Federal
8	Gasoline - Premium	4,000	Currently in use	Federal
9	Gasoline - Non Ethanol	4,000	Currently in use	Federal

#### **Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

#### **Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing

## **Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing

#### **Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

**Special Contingencies** 

# **Summary of Work**

Removing Anodes Per NOV

# PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest Tank Testing, LLC 2008 Medical Center Dr Monticello, IL 61856

Daniel J. Starke

Contact Person: Stephen T. Hall

Phone: 217/714-4305

Email: midwesttanktestingsth@aol.com Contractor License # IL002461 Exp. 1/2/2026

Sincerely,

Daniel Starks