



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1038403  
Permit #: 01399-2024UPG  
Request Rec'd: 11/01/2024  
Approval Date: 11/01/2024 DS  
Permit Expires: 05/01/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Road Ranger, LLC 1501 Woodfield Rd., Suite 300 S Schaumburg, IL 60173 Cook County Contact: John Carabelli 815/387-1700	<b>FACILITY</b> - name and address where tanks are located: Road Ranger #210 890 East Highway 38 Rochelle, IL 61068 Ogle County Contact: Suzie Lange 815/961-1700
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser - New vapor riser	New
Piping	Other Steel Riser - New fill riser	New

**Summary of Work**

Installing new fill and vapor risers, overspill bucket, overfill drop tube and vapor bucket on Regular Tank # 3

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks