



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4021245
Permit #: 01405-2024UPG
Request Rec'd: 11/01/2024
Approval Date: 11/01/2024 DS
Permit Expires: 05/01/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: M & S Holdings Group, LLC 536 CR 800N Findlay, IL 62534 (None) County Contact: Shawn Starwalt 217/294-1131 | FACILITY - name and address where tanks are located: Findlay Marina 536 County Road 800 North Findlay, IL 62534 Shelby County Contact: Shawn Starwalt 217/294-1131 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 3 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 |

Summary of Work

Adding CSLD software to existing TLS-350 Veeder Root Automatic Tank Gauge.

Special Contingencies

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| W J Scott Company 3861 Tozer Road Springfield, IL 62707 | Contact Person: Jim Scott Phone: 217/787-6081 Email: serwjs@comcast.net Contractor License # IL1949 Exp. 4/18/2026 |

Sincerely,

Daniel Starks