

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2023183
Permit #: 01412-2024CAT
Request Rec'd: 11/04/2024
Approval Date:11/04/2024 DS
Permit Expires: 05/06/2025

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS
- Corporation, partnership, or other business entity:
7204 Washington Real Estate, Inc.
7204 W. Washington
Forest Park. IL 60130

Forest Park, IL 60130 Cook County

Contact: Bijumon Poothurail 773/791-9599

FACILITY - name and address where tanks are located:

Amoco 5313

7204 W. Washington Street Forest Park, IL 60130

Cook County

Contact: Siby Aernat 708/366-4900

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 3 | Gasoline - Premium | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------------|---------------------------------------|---|
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating |
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------------|--|---|
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating |
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------------|--|---|
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating |
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

CP Impressed repair on all (3) Tanks & (3) Lines for Reg, Pre, Diesel. Installing new Impressed Anodes on tanks & Lines also installing a new 10 way shunt box, & new Red light & new Amp Meter

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC

658 North Progress Drive PO Box 80265

Saukville, WI 53080

Daniel J. Starke

Contact Person: Kylie Krombach

Phone: 262/268-1150

Email: frankg@protanicinc.com

Contractor License # IL1413 Exp. 9/26/2026

Sincerely,

Daniel Starks