



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	6003046
Permit #:	01425-2024UPG
Request Rec'd:	11/06/2024
Approval Date:	11/07/2024 DS
Permit Expires:	05/07/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: N. D. Investment Co. 11837 Lackland Road St. Louis, MO 63146 (None) County Contact: Dahyabhai Patel 618/531-5152	FACILITY - name and address where tanks are located: Quick Stop 2605 College Avenue Alton, IL 62002 Madison County Contact: Dahyabhai Patel 618/465-5011
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Regular	10,000	Currently in use	Federal
9	Gasoline - Mid-grade	5,000	Currently in use	Federal
10	Gasoline - Premium	5,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	Replacing - Piping - Fiberglass Single Wall Piping A.O. Smith

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	Replacing - Piping - Fiberglass Single Wall Piping A.O. Smith

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	Replacing - Piping - Fiberglass Single Wall Piping A.O. Smith

Summary of Work

Ameron gas hit the vent lines while boring for a new gas line. The vents lines will be uncovered and the existing vent lines will be repaired as needed.


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
128 Millwell Drive
Maryland Heights, MO 63043

Contact Person: Terry Smith
Phone: 314/267-1231
Email: terrys@unitedpetro.com
Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks