



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY
Facility #: 2001171
Permit #: 01363-2024REM
Request Rec'd: 10/22/2024
Approval Date: 10/25/2024 SB
Revision Date: 11/07/2024 DS
Permit Expires: 04/25/2025

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Pfanstiehl, Inc. 1219 Glen Rock Avenue Waukegan, IL 60085 Lake County Contact: Tony Lockett 847/599-5125	FACILITY - name and address where tanks are located: Pfanstiehl 1219 Glen Rock Avenue Waukegan, IL 60085 Lake County Contact: Tony LOCKETT 847/599-5125
--	--

Tanks on the Permit

Tank #	Capacity	Product	Last Used Date
19	9,000	Acetone	10/01/1997
20	6,000	Acetone	10/01/1997
21	4,000	Hexane	10/01/1997

Summary of Work

We will cut and break the top layer of concrete and remove the rubble and excavate around the tanks that are inside the building to expose the three 3,000 gallon UST's which are expected to be filled with concrete. Then we will check the tanks for fulness and LEL and, if approved by the Fire Marshal we will pull and remove the UST's.

Special Contingencies

Revision Reason:

Corrected tank numbers

The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
AQS Services Inc 443 South Clay Street Hinsdale, IL 60521	Contact Person: William Anthony Phone: 630/789-3345 Email: aqsservices@comcast.net Contractor License # IL1913 Exp. 5/11/2026

Sincerely,

Shelly Bradley

Shelly Bradley