



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Extended**

**FOR OFFICE USE ONLY**  
Facility #: 4007178  
Permit #: 00718-2024UPG  
Request Rec'd: 06/12/2024  
Approval Date: 06/12/2024 DS  
Extension Date: 11/12/2024  
Permit Expires: 06/12/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Sumark Normal, LLC 409 S. Prospect, Suite F Bloomington, IL 61704 McLean County Contact: Michele Alvarado 309/585-3536	<b>FACILITY</b> - name and address where tanks are located: Mac's #1204 309 Landmark Drive Normal, IL 61761 McLean County Contact: Carrie Burtis 630/942-5363
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New

**Summary of Work**

repairing a section of vent line  
using dualoy 22370802

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel Starks