



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2010042
Permit #: 01446-2024UPG
Request Rec'd: 11/11/2024
Approval Date: 11/12/2024
Permit Expires: 05/13/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ihsan Sweiss, Shwehdeh Abu Khalil 410 Shadow Creek Drive Palos Heights, IL 60463 Cook County Contact: Irar Sweiss 708/293-8850	FACILITY - name and address where tanks are located: Damen Augusta Gas Station 1949 W. Augusta Blvd. Chicago, IL 60622 Cook County Contact: Shwehdeh Khalil 773/276-6496
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	6,000	Currently in use	Federal
4	Gasoline - Regular	15,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket


Summary of Work

Installing new fill risers, replacing overspill buckets and overfill drop tubes on Premium tank# 3 and Regular tank# 4

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

A handwritten signature in black ink that reads "Seán Keane". The signature is written in a cursive style with a horizontal line underneath it.

Sean Keane