



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2005834
Permit #: 01451-2024REM
Request Rec'd: 11/07/2024
Approval Date: 11/12/2024 DS
Permit Expires: 05/13/2025

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Township of Warren 17801 W. Washington St. Gurnee, IL 60031 Lake County Contact: Gerald E Rudd 847/244-1101	FACILITY - name and address where tanks are located: Township of Warren 17801 Washington St Gurnee, IL 60031 Lake County Contact: Gerald E Rudd 847/244-1101
---	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
3	4,000	Diesel Fuel	
4	4,000	Gasoline - Regular	

Summary of Work

Removing existing single wall fiberglass pipe for Gas and Diesel lines. Vents to remain.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Petroleum Technologies Equipment, Inc. 8447 West 44th Place Lyons, IL 60534	Contact Person: Thomas Doherty Phone: 708/243-1108 Email: tjdpte@aol.com Contractor License # IL2051 Exp. 1/17/2026

Sincerely,

Daniel Starks