

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2039549
Permit #: 01454-2024UPG
Request Rec'd: 11/12/2024
Approval Date:11/12/2024 DS
Permit Expires: 05/13/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Anabi Real Estate Development, LLC, Designated Series JJ

1450 N. Benson Avenue, Suite A

Upland, CA 91786 (None) County

Contact: David Garcia 909/394-4728

FACILITY

- name and address where tanks are located:

Midwest Convenience, Inc. 1300 Normantown Road Romeoville, IL 60446

Will County

Contact: Nicole Brown 815/293-2740

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Mid-grade	12,000	Currently in use	Federal
4	B-11	12,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser - New Vapor Riser	New
Piping	Other Steel Riser - New Fill Riser	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New

Summary of Work

Tank # 3 Mid Grade Installing new fill and vapor risers, replacing overspill bucket, overfill drop tube and vapor bucket Tank # 4 B-11 Installing new fill riser, replacing overspill bucket and overfill drop tube

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448 Contact Person: Ron Anderson

Phone: 708/560-5590

Email: keith@andersonpump.com

Contractor License # IL002275 Exp. 5/21/2026

Sincerely, Daniel J. Starks

Daniel Starks