

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 3038878
Permit #: 01478-2024UPG
Request Rec'd: 11/18/2024
Approval Date:11/18/2024 DS
Permit Expires: 05/20/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Balraj Sandhu 700 S. Main St.

Creve Coeur, IL 61610

Tazewell County

Contact: Balraj Sandhu 219/617-7354

FACILITY

- name and address where tanks are located:

C-Store Development Company

700 S. Main St.

Creve Coeur, IL 61610

Tazewell County

Contact: 309/694-9043

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New

Summary of Work

Changing from ball cage float to overfill drop tube valve due to ball cage missing in tank.

Special Contingencies

NOTE: No overfill device listed in our database which is why this is a "new" install instead of a replacement

PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company 2421 Washington Road

Caniel J. Starke

Washington, IL 61571

Contact Person: Cheri McCoy

Phone: 309/694-8224

Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026

Sincerely,

Daniel Starks