



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Revised**

**FOR OFFICE USE ONLY**  
Facility #: 2046227  
Permit #: 01486-2024UPG  
Request Rec'd: 11/12/2024  
Approval Date: 11/19/2024 DS  
Revision Date: 11/19/2024 DS  
Permit Expires: 05/20/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Lenny's Gas N Wash Plainfield, LLC 8200 185th St., Suite K Tinley Park, IL 60487 (None) County Contact: Leonard McEnery 708/444-0117	<b>FACILITY</b> - name and address where tanks are located: Lenny's Gas N Wash Plainfield, LLC 25653 W. Lockport Road Plainfield, IL 60544 Will County Contact: Kelli States 708/444-0117Ext.1
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal
4	E85	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Removing
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Removing

### Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Removing
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

### Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Removing

### Summary of Work

Remove CSLD from site and use sensors as form of Leak Detection.


### Special Contingencies

#### Revision Reason:

Changed leak detection to show removal of CSLD but ATG remained

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: Steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks