



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2009149  
Permit #: 01496-2024UPG  
Request Rec'd: 11/19/2024  
Approval Date: 11/19/2024 DS  
Permit Expires: 05/20/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |  |
|--|--|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>I K I Real Estate, LLC<br>22W70 Butterfield Rd.<br>Glen Ellyn, IL 60137<br>Du Page County<br>Contact: Brahim Istambouli 630/915-7491 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Mobil Glen Ellyn<br>22W070 Butterfield Rd.<br>Glen Ellyn, IL 60137<br>Du Page County<br>Contact: Ibrahim Istambouli 630/915-7491 |
|--|--|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 7      | Gasoline - Regular | 12,000   | Currently in use | Federal          |
| 8      | Gasoline - Regular | 10,000   | Currently in use | Federal          |
| 9      | Gasoline - Premium | 10,000   | Currently in use | Federal          |
| 10     | Diesel Fuel        | 8,000    | Currently in use | Federal          |

**Tank 7 Equipment**

| Equipment Type             | Permit Equipment   | Action  |
|----------------------------|--|---|
| Spill Containment Device   | Double Wall Spill Bucket                                     | Replacing - Spill Contain Device - Single Wall Spill Bucket |
| Piping                     | Fiberglass Single Wall Piping Ameron 4000 L single wall vent | New   |
| Overfill Prevention Device | Overfill Drop Tube Valve                                     | Replacing - Overfill Prev Device - Overfill Alarm           |

**Tank 8 Equipment**

| Equipment Type             | Permit Equipment   | Action  |
|----------------------------|--|---|
| Piping                     | Fiberglass Single Wall Piping Ameron 4000 L single wall vent | New   |
| Overfill Prevention Device | Overfill Drop Tube Valve                                     | Replacing - Overfill Prev Device - Overfill Alarm           |
| Spill Containment Device   | Double Wall Spill Bucket                                     | Replacing - Spill Contain Device - Single Wall Spill Bucket |

**Tank 9 Equipment**

| Equipment Type             | Permit Equipment   | Action  |
|----------------------------|--|---|
| Piping                     | Fiberglass Single Wall Piping Ameron 4000 L single wall vent | New   |
| Overfill Prevention Device | Overfill Drop Tube Valve                                     | Replacing - Overfill Prev Device - Overfill Alarm           |
| Spill Containment Device   | Double Wall Spill Bucket                                     | Replacing - Spill Contain Device - Single Wall Spill Bucket |

**Tank 10 Equipment**

| Equipment Type             | Permit Equipment   | Action  |
|----------------------------|--|---|
| Piping                     | Fiberglass Single Wall Piping Ameron 4000 L single wall vent | New   |
| Overfill Prevention Device | Overfill Drop Tube Valve                                     | Replacing - Overfill Prev Device - Overfill Alarm           |
| Spill Containment Device   | Double Wall Spill Bucket                                     | Replacing - Spill Contain Device - Single Wall Spill Bucket |


**Summary of Work**

RELOCATE FIBERGLASS SINGLEWALL VENTS FROM FOUR (4) EXISTING USTS TO BUILDING NORTH OF TANKS DUE TO IDOT PROJECT #60P75. REMOVING EXISTING VENT LINES AND REMOTE FILLS AND INSTALLING DOUBLE WALL SPILL BUCKETS AND OVERFILL DROP TUBES ON TOP OF TANKS

**Special Contingencies**

| PERSON, FIRM OR COMPANY PERFORMING WORK:  |   |
|---|---|
| Superior Petroleum Marketers, Inc.<br>2336 Albright Lane P. O.Box 4648<br>Wheaton, IL 601894648 | Contact Person: Steve Tuttle<br>Phone: 630/588-1198<br>Email: tuttle.steve11@gmail.com<br>Contractor License # IL2087 Exp. 2/4/2026 |

Sincerely,



Daniel Starks