



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2015461
Permit #: 01499-2024UPG
Request Rec'd: 11/20/2024
Approval Date: 11/20/2024 DS
Permit Expires: 12/03/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Nice Group, Inc. 1001 East Algonquin Rd. Arlington Heights, IL 60005 Cook County Contact: Siny Thomas 847/593-7166 | FACILITY - name and address where tanks are located: TSS Oil, Inc. 1651 Algonquin Road SWC Algonquin Rd. & Busse Rd. Mount Prospect, IL 60056 Cook County Contact: Siny Thomas 847/593-7166 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 5 | Diesel Fuel | 3,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
| Piping | Shear Valves | New |

Summary of Work

Work for emergency permit - Tech found bad impact valve under Diesel dispenser 9/10. Replacing impact valve.

Special Contingencies

NOTE: UDC must be installed under a separate upgrade permit if not already existing

| | |
|---|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2026 |

Sincerely,

Daniel Starks