

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2006911
Permit #: 01514-2024UPG
Request Rec'd: 11/22/2024
Approval Date:11/25/2024 DS
Permit Expires: 05/28/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

RDK Ventures, LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County

Contact: Elizabeth Sauser 773/456-5280

FACILITY

- name and address where tanks are located:

Circle K #6755 10258 South Kedzie Evergreen Park, IL 60642 Cook County

Contact: Jonathan Ross 812/379-9227

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Premium	12,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser - New vapor riser being installed	New
Piping	Other Steel Riser - New fill riser being installed	New

Summary of Work

Tank # 5 Premium: Installing new fill and vapor risers, Replacing overspill bucket, vapor bucket and overfill drop tube

Special Contingencies

Janiel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/506-5590
Email: keith@andersonpump.com
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks