



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2047837  
Permit #: 01522-2024ABN  
Request Rec'd: 11/25/2024  
Approval Date: 11/25/2024 DS  
Permit Expires: 05/28/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Martin D Katz, Trustee, Joseph E Katz and Sarane E Katz Trusts 1504 Schuyler Road Beverly Hills, CA 90210 Contact: Marty Katz 213/268-5006	<b>FACILITY</b> - name and address where tanks are located: Hometown Coffee Northbrook 1290 Shermer Rd Northbrook, IL 60062 Cook County Contact: Marty Katz 213/268-5006
--	--

**Tanks on the Permit**

Tank #	Capacity	Product	Fill Material	Comments
1	1,000	Heating Oil	Inert material mixed with portland cement	

**Explanation of Waiver for Abandonment**

Abandonment of (1) 1,000 gallon heating oil UST. Abandonment is required due to tank location <5' from building foundation and underneath air conditioning equipment

**Location of Tanks Being Abandoned**

Abandonment of (1) 1,000 gallon heating oil UST. Abandonment is required due to tank location <5' from building foundation and underneath air conditioning equipment

**Location of Piping Being Abandoned**

Abandonment of (1) 1,000 gallon heating oil UST. Abandonment is required due to tank location <5' from building foundation and underneath air conditioning equipment

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Daniel Starks