



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047838
Permit #: 01531-2024ABN
Request Rec'd: 11/26/2024
Approval Date: 11/26/2024 DS
Permit Expires: 05/28/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Metra 547 W Jackson Blvd Chicago, IL 60661 Cook County Contact: Bill Wettstein 312/322-6934	FACILITY - name and address where tanks are located: Schiller Park Metra Warehouse 9700 Montrose Avenue Schiller Park, IL 60176 Cook County Contact: Murphy 312/520-5826
---	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
1	3,000	Heating Oil	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Approximate 3,000-gallon (8' D) tank is located within 21" of a slab on grade building, therefore there is a structural concern with the building. Additionally, there is an electrical line located near the end of the UST and along the west side.

Location of Tanks Being Abandoned

Approximate 3,000-gallon (8' D) tank is located within 21" of a slab on grade building, therefore there is a structural concern with the building. Additionally, there is an electrical line located near the end of the UST and along the west side.

Location of Piping Being Abandoned

No piping mentioned nor shown in site plan

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: ademauro@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Daniel Starks