



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022767
Permit #: 01535-2024REM
Request Rec'd: 11/27/2024
Approval Date: 11/27/2024 SK
Permit Expires: 05/28/2025

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Belmont 5800 Real Estate, Inc. 5800 W. Belmont Avenue Chicago, IL 60634 Cook County Contact: Amal Chackochan 847/877-5799	FACILITY - name and address where tanks are located: Belmont 5800 Real Estate, Inc. 5800 W. Belmont Avenue Chicago, IL 60634 Cook County Contact: Amal Chackochan 847/877-5799
---	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
6	10,000	Gasoline - Regular	
7	10,000	Gasoline - Premium	
8	10,000	Diesel Fuel	

Summary of Work

Removing old steel piping only. Re using existing tanks.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/906-6178 Email: hoyt@andersonpump.com Contractor License # IL002275 Exp. 6/10/2025

Sincerely,

Sean Keane