



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1038981  
Permit #: 01536-2024UPG  
Request Rec'd: 11/25/2024  
Approval Date: 12/01/2024 DS  
Permit Expires: 06/03/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                                                        |                                                                                                                                                                                            |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Pilot Travel Centers, LLC<br>5508 Lonas Rd.<br>Knoxville, TN 37909<br>Knox County<br>Contact: Joey Cupp 865/588-7488 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Flying J Travel Plaza #644<br>343 Civic Road<br>La Salle, IL 61301<br>LaSalle County<br>Contact: Rani Baily 815/220-0611 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1      | B-99               | 20,000   | Currently in use | Federal          |
| 2      | Diesel Fuel        | 20,000   | Currently in use | Federal          |
| 3      | Diesel Fuel        | 20,000   | Currently in use | Federal          |
| 4      | Gasoline - Regular | 20,000   | Currently in use | Federal          |
| 5      | Gasoline - Premium | 12,000   | Currently in use | Federal          |

**Tank 1 Equipment**

| Equipment Type        | Permit Equipment                                | Action                                                                                |
|-----------------------|-------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD |

**Tank 2 Equipment**

| Equipment Type        | Permit Equipment                                | Action                                                                                |
|-----------------------|-------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD |

**Tank 3 Equipment**

| Equipment Type        | Permit Equipment                                | Action                                                                                |
|-----------------------|-------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD |

**Tank 4 Equipment**

| Equipment Type        | Permit Equipment                                | Action                                                                                |
|-----------------------|-------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD |

### Tank 5 Equipment

| Equipment Type        | Permit Equipment                                | Action                                                                                |
|-----------------------|-------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD |

### Summary of Work

REPLACED THE EXISTING TLS WITH A TLS 450 PLUS

### Special Contingencies

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: 314/772-4501  
Email: testing@neumayerequipment.com  
Contractor License # IL1502 Exp. 3/26/2026

Sincerely,



Daniel Starks