



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	6024209
Permit #:	01552-2024REM
Request Rec'd:	12/03/2024
Approval Date:	12/03/2024 DS
Permit Expires:	06/03/2025

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances**

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176 . The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Caseyville BP, Inc. 2 Rauckman Road Caseyville, IL 622322300 St. Clair County Contact: Sanjay Patel 618/698-0541	- name and address where tanks are located: Caseyville BP #2 Rauckmann Road I-64 & IL 157 Caseyville, IL 622322300 St. Clair County Contact: Sanjay Patel 618/698-0541

**Tanks on the Permit For Piping Only**

Tank #	Capacity	Product	Last Used Date
1	10,000	Gasoline - Regular	
2	10,000	Gasoline - Regular	
3	10,000	Gasoline - Premium	

**Summary of Work**

Remove the existing product lines and islands. New piping and sumps to be installed under an upgrade permit

**Special Contingencies**

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

Daniel Starks