



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047346
Permit #: 01554-2024UPG
Request Rec'd: 12/03/2024
Approval Date: 12/04/2024 DS
Permit Expires: 06/04/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Lenny's Gas N Wash Cicero and Pershing, LLC 8200 185th Street, Suite K Tinley Park, IL 60487 (None) County Contact: Leonard McEnery 708/805-2525	FACILITY - name and address where tanks are located: Lenny's Gas N Wash Cicero and Pershing, LLC 3800 S. Cicero Avenue Stickney, IL 60402 Cook County Contact: Patrick Clarke 708/805-2525
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	20,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal
4	E85	10,000	Currently in use	Federal
5	Diesel Fuel	6,000	Currently in use	Federal
6	Diesel Fuel	20,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD

Summary of Work

Remove CSLD from site.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: Steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks