



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY
Facility #: 2017661
Permit #: 00824-2023INS
Request Rec'd: 07/24/2023
Approval Date: 07/26/2023
Extension Date: 12/04/2024
Permit Expires: 07/29/2025

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: East-West Properties, LLC 8603 W. 142nd Street Orland Park, IL 60461 Cook County Contact: Muhammad Khan 773/490-3696 | FACILITY - name and address where tanks are located: BP 119 S. Cicero Avenue Chicago, IL 60644 Cook County Contact: Muhammad Khan 773/490-3696 |
|--|---|


Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|----------------------|------------------|
| 12 | Gasoline - Regular | 12,000 | Installed/Not in Use | Federal |
| 13 | Gasoline - Premium | 4,000 | Installed/Not in Use | Federal |
| 14 | Diesel Fuel | 4,000 | Installed/Not in Use | Federal |
| 15 | E85 | 4,000 | Installed/Not in Use | Federal |


Tank 12 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 Plus | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Tank | Composite Double Wall Lannon | New |
| Piping | Flexible Double Wall Franklin Fueling Systems UPP | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Flex Connector Steel | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Piping | Other Steel Riser | New |
| Piping | Other Submersible Pump | New |
| Corrosion Protection - Tank | Composite Non-Corrosive | New |
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |

Tank 13 Equipment

| Equipment Type | Permit Equipment | Action |
|---|--|---------------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Piping | Flexible Double Wall Franklin Fueling Systems UPP | New |
| Tank | Composite Double Wall Lannon | New |
| Corrosion Protection - Tank | Composite Non-Corrosive | New |
| Piping | Other Submersible Pump | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Piping | Single Wall STP/Tanktop Sump | New |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Other Steel Riser | New |
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 Plus | New |
| Piping | Flex Connector Steel | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Extractor Fitting Valves | New |
| Spill Containment Device | Double Wall Spill Bucket | New |

Tank 14 Equipment

| Equipment Type | Permit Equipment | Action |
|---|--|---------------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Piping | Flexible Double Wall Franklin Fueling Systems UPP | New |
| Tank | Composite Double Wall Lannon | New |
| Corrosion Protection - Tank | Composite Non-Corrosive | New |
| Piping | Other Submersible Pump | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Piping | Single Wall STP/Tanktop Sump | New |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Other Steel Riser | New |
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 Plus | New |
| Piping | Flex Connector Steel | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Extractor Fitting Valves | New |
| Spill Containment Device | Double Wall Spill Bucket | New |

Tank 15 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Piping | Flexible Double Wall Franklin Fueling Systems UPP | New |
| Tank | Composite Double Wall Lannon | New |
| Corrosion Protection - Tank | Composite Non-Corrosive | New |
| Piping | Other Submersible Pump | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Other Steel Riser | New |
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 Plus | New |
| Piping | Flex Connector Steel | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Extractor Fitting Valves | New |
| Spill Containment Device | Double Wall Spill Bucket | New |

Dispensers on the Permit

| Dispenser | Action |
|----------------|-----------------|
| Dispenser-1/2 | Replacing - 1/2 |
| Dispenser- 3/4 | Replacing - 3/4 |
| Dispenser-5/6 | Replacing - 5/6 |
| Dispenser-7/8 | Replacing - 7/8 |
| 9/10 | Removing |

Dispenser Dispenser-1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser Dispenser- 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser Dispenser-5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser Dispenser-7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
|----------------|------------------|--------|

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.

There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

We are installing new Tanks, Piping, UDCs, Tank top sumps and islands

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504 | Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025 |

Sincerely,

sean.keane