



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2017666
Permit #: 01562-2024CAT
Request Rec'd: 12/05/2024
Approval Date: 12/05/2024 SK
Permit Expires: 06/05/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: M & S Gas & Food Inc 3731 W Roosevelt Chicago, IL 60624 Cook County Contact: Mohamed Yafai 773/542-8540	FACILITY - name and address where tanks are located: M & S Gas & Food Inc 3731 W Roosevelt Rd Chicago, IL 60624 Cook County Contact: Abdullah Aldeiban 773/542-8540
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Gasoline - Regular	12,000	Currently in use	Federal
14	Kerosene	6,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

Tank 14 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

The applicaiotn is for adding sacrificial (High Potential Magnesium Anodes) on Tanks 11 (RUL-West) and 14 (Kerosene), and the product piping which failed in recent testing. Expected anode locations are shown on the drawing.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Advanced Corrosion Control Technologies., Inc. 4664 North DuBay Drive Mosinee, WI 54455	Contact Person: Timothy Sievert Phone: 262/960-3665 Email: timothysievert@gmail.com Contractor License # IL2072 Exp. 3/22/2026

Sincerely,

Sean Keane