

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2047459
Permit #: 01565-2024UPG
Request Rec'd: 12/05/2024
Approval Date:12/05/2024 DS
Permit Expires: 06/05/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Lenny's Gas N Wash Plano, LLC

8200 185th Street Tinley Park, IL 60487

Contact: Leonard McEnery 708/444-0117

FACILITY

- name and address where tanks are located:

Lenny's Gas N Wash Plano LLC

10000 E. Route 34 Plano, IL 60545 Kendall County

Contact: Leonard McEnery 708/444-0117

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	6,000	Currently in use	Federal
2	E85	10,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal
4	Gasoline - Regular	20,000	Currently in use	Federal
5	Diesel Fuel	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection -	Automatic Tank Gauging Veeder Root	Replacing - Leak Detect - Tank - Automatic Tank Gauging
Tank	TLS 450 Plus	Veeder Root TLS 450 Plus with CSLD
Leak Detection -	Non-Discriminating Interstitial Monitoring	Replacing - Leak Detect - Tank - Non-Discriminating
Tank	Sensors With Monitor	Interstitial Monitoring Sensors

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection -	Non-Discriminating Interstitial Monitoring	Replacing - Leak Detect - Tank - Non-Discriminating
Tank	Sensors With Monitor	Interstitial Monitoring Sensors
Leak Detection -	Automatic Tank Gauging Veeder Root	Replacing - Leak Detect - Tank - Automatic Tank Gauging
Tank	TLS 450 Plus	Veeder Root TLS 450 Plus with CSLD

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection -	Non-Discriminating Interstitial Monitoring	Replacing - Leak Detect - Tank - Non-Discriminating
Tank	Sensors With Monitor	Interstitial Monitoring Sensors
Leak Detection -	Automatic Tank Gauging Veeder Root	Replacing - Leak Detect - Tank - Automatic Tank Gauging
Tank	TLS 450 Plus	Veeder Root TLS 450 Plus with CSLD

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection -	Non-Discriminating Interstitial Monitoring	Replacing - Leak Detect - Tank - Non-Discriminating
Tank	Sensors With Monitor	Interstitial Monitoring Sensors
Leak Detection -	Automatic Tank Gauging Veeder Root	Replacing - Leak Detect - Tank - Automatic Tank Gauging
Tank	TLS 450 Plus	Veeder Root TLS 450 Plus with CSLD

Summary of Work Remove CSLD from site.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:		
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/478-6190 Email: Steve@ndersonpump.com Contractor License # IL002275 Exp. 5/21/2026	

Sincerely, Daniel J. Starks

Daniel Starks